



YES	NO	NA
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

10. Is every bathroom door at least 24" wide? (LSC 7.2.1.2.4)

11. Is every bathroom door lock operable from the outside with a readily accessible device? (LSC N-32.2.2.5.5 E-33.2.2.5.5)

12. If clients are permitted to be located in the basement are there two approved ways out? (LSC N-32.2.2.2.2 E-33.2.2.2.2)

*(Note: One way out must be a door leading directly to the outside with a vertical travel distance of no more than 8 feet. The second way out can be a window at least 20" wide, 24" high and must be operable without tools.)*

13. Is heating equipment an approved type, clean and in good working condition? (LSC N-32.2.5.2.3 E-33.2.5.2.3)

*(Note: Unvented fuel-fired room heaters shall not be permitted.)*

14. Is heating equipment in spaces occupied by clients provided with partitions? Screens, or other means to protect children under six years of age from hot surfaces and open flames? (LSC N-32.2.3.2.4 E-33.2.3.2.4)

*(Note: If solid partitions are used, provisions shall be made to ensure adequate air for combustion and ventilation.)*

15. Are gas appliances equipped with a gas shut-off within 6 feet of the appliance? (UPC 1212.4)

16. Is the hot water heater equipped with a relief valve and a drain line that extends between 6" to 24" from the floor? (UPC 608.5)

17. Is storage of combustible materials maintained at least 36" from heat producing appliances such as furnaces, hot water heaters and dryers? (IFC 304, 305, 315)

18. Are breaker/fuse boxes accessible and maintained with 30 inches in width, 36 inches depth and 78 inches in height of clear space in front of the panel with breakers free to operate? (IFC 605.3)

19. Is electrical wiring free from hazardous conditions? (IFC 605.3, 605.4, 605.5, 605.6)

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Business Owner: \_\_\_\_\_

Inspected by: \_\_\_\_\_

Business Owner: \_\_\_\_\_

Re-inspected by: \_\_\_\_\_

New  Existing